

**ADDENDUM #9****ITB# 2021-011****PROJECT: WASTEWATER PUMP STATION IMPROVEMENTS****DATE: 04/19/2022**

- A. **The purpose of this addendum is to answer questions submitted by the vendors by the 4 p.m. Question submittal deadline.**

Question 1: WASD specs. & standards require a motor & control connection box in between the wet-well & the Motor Control Panel, & located no further than 6' from the well. Please advise if required for these pump stations.

Answer 1: **A motor & control connection box between the wet-well & the control panel is not required. Bid the project as shown on the electrical plans.**

Question 2: Estimated Value/Budget of this project.

Answer 2: **This number cannot be determined until all proposals have been received.**

Question 3: Is the City willing to provide Sci Text Controller for these projects? Since the controller (Sci-Text) is sole source it does not allow for other pump suppliers to be competitive on this bid?

Answer 3: **The Contract, if awarded, will be on the basis of material and equipment described in the Drawings or specified in the Specifications without consideration of possible substitute or "or-equal" items. Whenever it is indicated in the Drawings or specified in the Specifications that a substitute or "or-equal" item of material or equipment may be furnished or used by Contractor if acceptable to Engineer, application for such acceptance will not be considered by Engineer until after the "effective date of the Agreement".**

Question 4: Wanted to reach out to you in regard to subject Grinder/Macerator for subject and see if you all would accept as an equal our Vogelsang Twin Shafted Grinder. I have attached our spec sheet as well as a Scope of Supply for this. Please let me know if there is anything else I can provide you at this time.

Answer 4: **See Answer 3 above.**

Question 5: Can you add Moyno as an approved manufacturer for the wastewater macerator assembly called out in Section 11330 ?

Answer 5: **See Answer 3 above.**



This Addendum to the proposal is issued to provide additional information and clarification to the original proposal and is hereby declared a part of the original proposal and documents. In case of conflict, this Addendum shall govern.

All other terms and conditions of this ITB remain unchanged.

This Addendum shall be considered an integral part of the ITB and Contract Documents and this Addendum must be signed and returned with your submittal **by 2:00 p.m. on April 29, 2022**, and acknowledged on Form 8.2, Designated in Section 8. Failure to comply may result in disqualification of your bid submittal.

Angela C. Atkinson

Angela Atkinson
Chief Financial Officer

Acknowledgement is hereby made of Addendum#9 to ITB# 2021-011: WASTEWATER PUMP STATION IMPROVEMENTS.

Authorized Signature

Firm

Printed, Title

Date

Email Address