

2025 NORTH BAY VILLAGE CONSUMER CONFIDENCE REPORT

Contaminant and Unit of Measurement	Dates of Sampling (Mo/Year)	AL Exceeded Yes/No	95th Percentile Result	Number of Sampling Exceeding AL	MCLG	AL (Action Level)	Likely Source of Contamination
Copper (Tap Water) (ppm)	2025	NO					Corrosion of Household plumbing Erosion of Natural Deposits
Lead (Tap Water) (ppb)	2025	NO					Corrosion of Household plumbing
Disinfectant	Date of Sampling	Federal MCL	Level Detected	Range of Results	State MCL	MCL	Likely Source of Contamination
Cloraminez (ppm)	January-December	MRDL = 4	1.15	1.13-1.23	MRDL = 4	NO	Water additives used to control microbes
Contaminant and Unit of Measurement Stage 2 Disinfectants and DBP	Date of Sampling	MCL Violation Yes/No	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Halohacetic Acid (ppb)	2025	NO	60.		N/A	60	By-product of Drinking Water disinfectant
Total Trihalomethanez (ppb)	2025	NO	9.7		N/A	80	By-product of Drinking Water disinfectant

We are required to monitor your drinking water for specific contaminants on a regular basis.

AL = Action Level

MRDL = Maximum residual disinfection level

MDRLG = Maximum residual disinfection level goal

ppb = Parts per billion or micrograms per liter (ug/L)

ppm = Parts per million or milligram per liter (mg/L)